

HUTCHINGS

Wm C & Lorraine F. Bindamour

2214-1540 ↑

Wiggin

2084-12 ↑

1971

Spahr

1735-184 ↑ 1964

Tarr

1687-377 ↑ 1963

Bertha Worth

1620-087 ↑ 1962

Bertha G. Chase

↑ 627-214

Leonard F. Smith

RD

N/F
Bertha G.
CHASE

N/F
Smith

N/F Bertha G.
CHASE

1620-087 =
ORIGINAL
DESCRIPTION
1962

Command= 210-

Point#, Start#-End# or G#= 1-200

Bearing	Distance	Elev	Descrip	Pnt.	Northing	Easting	Type
-----09-02-2023-----15:21:25-----D:\BENCH FILES\BM6							
		50.00	SETHUB	1	5000.0000	5000.0000	
		41.10	SETHUB	2	5103.0397	5059.4900	TRA
		67.17	CORFNC	3	4926.3306	4980.3694	SS
		74.36	GND	4	4904.6401	4979.4454	SS
		75.63	GND	5	4881.7681	5017.9718	SS
		73.20	GND	6	4862.0301	5067.8481	SS
		62.11	FNCPOST	7	4921.5076	5030.9937	SS
		57.06	FNC	8	4916.9649	5083.8401	SS
		55.25	BLD5'C	9	4919.7147	5118.1178	SS
		51.72	@WLL	10	4960.4066	5119.4280	SS
		48.09	WALL	11	4990.0074	5122.1219	SS
		44.24	WALL	12	5037.5943	5123.9857	SS
		43.55	CORHSE	13	5041.3389	5078.5909	SS
		43.73	CORHSE	14	5042.2340	5054.0705	SS
		44.00	BS	15	5028.4672	5052.0773	SS
		44.35	BS	16	5020.0510	5091.8980	SS
		47.14	GND	17	4990.9199	5090.2845	SS
		50.42	EDGWDS	18	4961.4032	5086.7294	SS
		48.94	EDGWDS	19	4983.0290	5034.9806	SS
		52.27	EDGWDS	20	4974.7138	5012.5514	SS
		53.24	EDWDSFNC	21	4985.5496	4981.3034	SS
		46.62	@BLDR*	22	5007.3196	5058.4535	SS
		47.72	BS	23	5000.5029	5022.9945	SS
		49.57	TS	24	4999.1075	5013.3001	SS
		46.92	TS	25	5022.7855	5022.5536	SS
		44.26	BSCRBOX	26	5034.7813	5040.7957	SS
		48.14	GND	27	5017.7754	5002.2718	SS
		49.13	@FNC	28	5015.9226	4982.8118	SS
		46.72	BMNL3CH	29	5043.5158	4984.6614	SS
		45.38	PIT	30	5053.0136	4999.1762	SS
		46.98	GND	31	5035.4518	5013.9291	SS
		43.93	BS	32	5055.9925	5035.2793	SS
		45.27	TS	33	5060.6228	5021.1309	SS

JOB #6 226HUTCH [200]

Bearing	Distance	Elev	Descrip	Pnt.	Northing	Easting	Type
-----09-02-2023-----15:21:25-----D:\BENCH FILES\BM6							
		45.08	FFL@CLSL	34	5060.3046	5054.9719	SS
		42.91	TOPTNK??	35	5061.5142	5051.7081	SS
		44.03	OUTDRN	36	5065.4945	5047.7448	SS
		43.62	DITCH	37	5065.7353	5041.6699	SS
		43.26	DITCH	38	5068.9606	5036.9161	SS
		44.18	BABYTREE	39	5080.0217	5023.4611	SS
		44.27	GND***	40	5089.0914	5008.9514	SS
		44.00	LT9CEDAR	41	5078.4252	4994.9132	SS
		43.70	BMNL6MP	42	5100.1641	4994.5924	SS
		43.70	GND	43	5077.6683	4968.8825	SS
		45.61	GND	44	5058.2800	4948.4005	SS
		44.31	GND	45	5072.0814	4936.1561	SS
		50.52	GND	46	5025.9189	4918.5127	SS
		57.59	GND	47	4992.1155	4902.8294	SS
		56.06	GND	48	4983.8694	4946.4884	SS
		43.55	L1.5COR	49	5100.5872	4984.3500	SS
		41.00	DITCH	50	5106.1634	4984.3949	SS
		41.24	DITCH	51	5106.8922	4930.9477	SS
		42.85	GND	52	5101.9480	4930.0746	SS
		41.96	EP	53	5111.6756	4932.2227	SS
		41.78	EP	54	5134.6063	4934.3190	SS
		38.04	OUTLET?	55	5140.6282	5024.5640	SS
		41.12	EP	56	5108.9026	5023.0284	SS
		39.16	INLET??	57	5104.5532	5022.5010	SS
		40.35	DITCHPI	58	5103.2943	5029.5711	SS
		42.17	DTCHWLL	59	5095.5794	5030.4427	SS
		42.96	DTCH**	60	5082.2328	5032.4106	SS
		43.51	CORHSE	61	5086.2885	5056.2065	SS
		43.16	BIGTREE	62	5092.4236	5042.5519	SS
		40.04	POL69316	63	5135.9737	5055.2954	SS
		44.12	GND	64	5073.6842	5041.4225	SS
		44.30	GND	65	5091.6270	5026.6146	SS
		42.43	CORHSE	66	5085.7644	5072.9176	SS
		41.75	CORFNC	67	5089.8799	5088.6698	SS
		44.10	WELL1.5	68	5074.5581	5114.4595	SS
		41.10	CORWLL	69	5086.9809	5125.1446	SS
		39.99	CLDREP20	70	5104.4224	5104.3187	SS

Point#, Start#-End# or G#= 4-

APPROVAL FOR CONSTRUCTION

N.H. DEPARTMENT OF ENVIRONMENTAL SERVICES
WATER SUPPLY & POLLUTION CONTROL DIVISION
P.O. BOX 95, 6 HAZEN DRIVE, CONCORD, NH 03302-0095

CA1996002426

APPROVAL NO.

CA1996002426

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

OWNER:

BRAD HUTCHINGS
122 BUNKER HILL AVE
STRATHAM NH 03885-

LOT 24 / N/A
PRE 67

Lot Numbers:
Subd. Appvl. No.:
Subd. Name:
County:
Registry Book No.:
Registry Page No.:
Probate Docket No.:
(If Applicable)

ROCKINGHAM
2214/3131
1540/0475

COPY SENT TO:

TOWN OF STRATHAM
10 BUNKER HILL AVENUE
STRATHAM NH 03885-

Type of System:
4 BR
600 GPD

Town/City Location:
STRATHAM

Street Location:
122 BUNKERHILL AVE

BY APPLICANT: PERMIT NO.

00348

STOCKTON SERVICES
PO BOX 1306
HAMPTON NH 03843-1306

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure.
(RSA 485-A:37)

It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal systems. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (Env-Ws 410.05)

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES
IN PLANS AS INDICATED BELOW CONDITIONS

1. THIS APPROVAL IS VALID FOR 90 DAYS FROM DATE OF SAID APPROVAL.
2. EXISTING SYSTEM TO BE DISCONTINUED AND FILLED.
3. PROVIDE A HEAVY SOIL BLANKET ON THE 3:1 SLOPES AND 1 SEED TO STABILIZE.
4. SEALANTS FOR PIPE PENETRATIONS TO BE AS APPROVED. NO ROOF TAR.
5. EXISTING PIPE AND OPEN DITCH TO BE REMOVED.
6. WAIVER GRANTED.

Approved this date: _____

Date amended: _____

By: _____

N.H. Water Supply & Pollution Control Division Staff

Amended by: _____

(OVER)

REVISED 8/91

199602707

APPLICANT'S

PERC TEST DATA

DATE 5/29/96 PERC RATE: 6 min / in

DESIGN LOADING: EXISTING 4 BEDROOMS

AREA REQUIRED: 900 (CHAMBERS) x 0.6 = 540 SF

AREA PROPOSED: 16 x 36 = 576 SF
(18 4'x8' CHAMBERS)

PROPOSED REPLACEMENT
SEPTIC SYSTEM PLAN
(EXISTING FAILED SYSTEM)

LOCUS: 122 BUNKER HILL AVE
STRATHAM, NH


OWNER: BRAD HUTCHINGS
122 BUNKER HILL AVE
STRATHAM, NH 03885

APPLICANT: STOCKTON SERVICES
PO BOX 1306
HAMPTON, NH 03842

DATE: 5/14/96 REV 6/14/96

APPROVAL: _____

226



RECEIVED
JUN 02 1996

ADVISE YOUR CONTRACTOR
OF REQUIRED CHANGES IN
PLANS AS INDICATED ON THIS
CONDITIONAL APPROVAL.

Signed Eric Thomas
Date 6-11-96

CA1996002426
REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
NH DEPT. OF ENVIRONMENTAL SERVICES
WATER SUPPLY & POLLUTION
CONTROL DIVISION

APPROVAL FOR CONSTRUCTION

N.H. DEPARTMENT OF ENVIRONMENTAL SERVICES
SUBSURFACE SYSTEMS BUREAU
P.O. BOX 95, 6 HAZEN DRIVE, CONCORD, NH 03302-0095
CA1999015137 APPROVAL NO. CA1999015137

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

OWNER:
OWNER: BRAD HUTCHINGS
122 BUNKER HILL AVENUE
STRATHAM NH 03885
Map No./Lot No.: 1540 / 2214
Subd. Appvl. No.: PRE 67
Subd. Name: JAVORRA 21HT
County: ROCKINGHAM
Registry Book No.: 2214
Registry Page No.: 1540
Probate Docket No.: (If Applicable)

COPY SENT TO:

TOWN OF STRATHAM
10 BUNKER HILL AVE
STRATHAM NH 03885
Type of System: 4 BR
RESPONSIBILITY OF THE OWNER TO CORRECT SUCH FAILURE
Town/City Location: STRATHAM

BY APPLICANT: PERMIT NO. 00348
Street Location: 122 BUNKER HILL AVENUE

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure.
(RSA 485-A:37)
It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal systems. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (Env-Ws 410.05)

STOCKTON SERVICES
PO BOX 1306
HAMPTON NH 03842

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES
IN PLANS AS INDICATED BELOW CONDITIONS

1. THIS APPROVAL IS VALID FOR 90 DAYS FROM DATE OF SAID APPROVAL.
2. NO ADDITIONAL LOADING WILL BE PERMITTED.
3. EXISTING SYSTEM TO BE DISCONTINUED AND FILLED.
4. THIS APPROVAL IS GRANTED ONLY TO IMPROVE AN EXISTING SITUATION.
5. WAIVER GRANTED.
6. PROVIDE A VENT IN THE PUMP CHAMBER.
7. EXISTING OPEN DITCH AND PIPE TO BE REMOVED.
8. PROVIDE A HEAVY SOIL BLANKET ON THE 3:1 SLOPES AND SEED TO STABILIZE.

Approved this date: 02/09/1999

By: ERIC J THOMAS

Date amended:
Revised 6/97

Amended by:

APPLICANT'S

199900723

ADVISE YOUR CONTRACTOR OF REQUIRED PERMITS IN PLANS AS INDICATED ON THIS CONDITIONAL APPROVAL.

PERC TEST DATA

DATE 5/29/96 PERC RATE:

6 min/in

Date

DESIGN LOADING:

EXISTING 4 BEDROOMS

AREA REQUIRED:

900 (CHAMBERS) x 0.6 = 540 SF

AREA PROPOSED:

16 x 36 = 576 SF PROVIDED
(18 4'x8' CHAMBERS)

PROPOSED REPLACEMENT

SEPTIC SYSTEM PLAN

(EXISTING FAILED SYSTEM)

LOCUS: 122 BUNKER HILL AVE

STRATHAM, NH

PREVIOUS APPROVAL CA1996002426 (EXPIRED)

OWNER: BRAD HUTCHINGS

RECEIVED 122 BUNKER HILL AVE

FEB 03 1999 STRATHAM, NH 03885

BY: RCD

APPLICANT:

STOCKTON SERVICES

PO BOX 1306

HAMPTON, NH 03842

5/14/96 RESUBMIT

DATE: REV 6/4/96 1/26/99

(SEE NOTE 9)

APPROVAL:

226 (99)

APPROVED
Town of Stratham
Septic System Examiner
Michael Connors
4/26/99

NEW HAMPSHIRE
Designer of
Subsurface Disposal
Systems

Ann W. Bialobrzeski
No. 348
Water Supply & Pollution Control